PRODUCT EVALUATION REPORT

- Florida Building Code - 8th Edition (2023) -

Per Rule 61G20-3 / Method 1 - D

FL #: **40096.5** **DATE:** 03/11/2025

Product Description

Manufacturer: **ECO WINDOW SYSTEMS, LLC**
Address: 8502 NW 80th St #103, Medley, FL 33166
Model Name: **ECO-Guard - Series 150 Aluminum Single Hung Window (L.M.I.)**
Maximum Load: +80.0 PSF / -120.0 PSF (Large Missile Impact)
Drawing No.: JA-1206-25, signed and sealed by Javad Ahmad, P.E. - FL License No. 70592

This product COMPLIES with the 2023 Florida Building Code - 8th Edition (2023 FBC) for use in the High-Velocity Hurricane Zone (HVHZ) per TAS 201/202/203.
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.
Comparative Analysis used: ◉ YES ○ NO

Mandatory Tests (Tested in accordance with AAMA 501 / 101 / I.S.2 / NAFS / TAS 202)					
TEST	**DESCRIPTION**	**TEST LOCATION**	**TEST REPORT DATE**	**TEST REPORT #**	**TEST SEALED BY**
TAS 202-94	Uniform Static Test	Fenestration Testing Laboratory, Inc.	02/08/2018	FTL-9886	Idalmis Ortega, P.E.
Supplemental Tests (Tested in accordance with TAS 201 and TAS-203)					
TEST	**DESCRIPTION**	**TEST LOCATION**	**TEST REPORT DATE**	**TEST REPORT #**	**TEST SEALED BY**
TAS 201 & TAS 203	Large Missile Impact & Cyclic Pressure Differentials	Fenestration Testing Laboratory, Inc.	02/08/2018	FTL-9886	Idalmis Ortega, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code - 8th Edition (2023 FBC).

JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER

Sealed: 03/11/2025

Evaluation Report Engineer:

Javad Ahmad, PE
FL P.E.# 70592
EB C.A.N. # 34254
JAVAD AHMAD PE, Inc.

THESE WINDOWS ARE RATED FOR LARGE & SMALL MISSILE IMPACT.
SHUTTERS ARE NOT REQUIRED.

SERIES–150 (L.M.I.)
ALUMINUM SINGLE HUNG WINDOW

DESIGN LOAD RATINGS FOR THESE WINDOWS TO BE AS PER CHARTS SHOWN ON SHEET 3.

APPROVAL APPLIES TO SINGLE UNITS OR SIDE BY SIDE COMBINATIONS OF S.H./S.H. OR SINGLE HUNG WITH OTHER WINDOW TYPES IN MODULES OF TWO OR MORE WINDOWS USING F.B.C. HVHZ APPROVED MULLIONS IN BETWEEN.

LOWER DESIGN PRESSURE FROM WINDOWS OR MULLION APPROVAL WILL APPLY TO ENTIRE SYSTEM.

THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).

1BY OR 2BY WOOD BUCKS & BUCK FASTENERS BY OTHERS, MUST BE DESIGNED AND INSTALLED ADEQUATELY TO TRANSFER APPLIED PRODUCT LOADS TO THE BUILDING STRUCTURE.

ANCHORS SHALL BE CORROSION RESISTANT, SPACED AS SHOWN ON DETAILS AND INSTALLED PER MANUF'S INSTRUCTIONS. SPECIFIED EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.


A LOAD DURATION INCREASE IS USED IN DESIGN OF ANCHORS INTO WOOD ONLY.

ALL SHIMS TO BE HIGH IMPACT, NON–METALLIC AND NON–COMPRESSIBLE.

MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF THE FLORIDA BLDG. CODE & ADOPTED STANDARDS.

THIS PRODUCT APPROVAL IS GENERIC AND DOES NOT PROVIDE INFORMATION FOR A SITE SPECIFIC PROJECT, i.e. LIFE SAFETY OF THIS PRODUCT, ADEQUACY OF STRUCTURE RECEIVING THIS PRODUCT AND SEALING AROUND OPENING FOR WATER INFILTRATION RESISTANCE ETC.
CONDITIONS NOT SHOWN IN THIS DRAWING ARE TO BE ANALYZED SEPARATELY, AND TO BE REVIEWED BY BUILDING OFFICIAL.

DESIGN LOAD SHOWN ARE BASED ON 'ALLOWABLE STRESS DESIGN (ASD)'.



TYPICAL ELEVATION
(TESTED UNIT)

FL#40096.5

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral,
FL 33126
Ph: (305) 424-8001
support@ja-pe.com
CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no.	JA-12062025	drawn by:	MA
date:	04/15/2025	check by:	BS

REVISION


No.	DATE	BY	DESCRIPTION

SERIES 150, ECO-GUARD ALUMINUM SINGLE HUNG WINDOW (L.M.I.)
LARGE MISSILE IMPACT RATED

ECO WINDOW SYSTEMS, LLC.
8502 N.W. 60th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902


JAVAD AHMAD LICENSE No. 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER

SEALED: 04-15-2025




GLASS TYPE 'G1'

7/16" OVERALL LAM. GLASS




GLASS TYPE 'G2'

15/16" OVERALL INSUL. LAM. GLASS



GLASS TYPE 'G3'

7/16" OVERALL LAM. GLASS



GLASS TYPE 'G4'

15/16" OVERALL INSUL. LAM. GLASS

GLAZING OPTIONS

FL#40096.5

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com

CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no.	JA 1206-25	drawn by:	MA
date:	04/15/2025	check by:	BS

REVISION

No.	DATE	BY	DESCRIPTION

SERIES 150 ECO-GUARD ALUMINUM SINGLE HUNG WINDOW (L.M.I)
LARGE MISSILE IMPACT RATED

eco window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902


JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER

SEALED: 04-15-2025

Equal Lites Windows
Design Load Capacity - PSF

Window Width (in.)	Glass Type	Window Height (in.)											
		38-3/8" (4)		50-5/8" (6)		63" (6)		76" (8)		84" (10)		96" (12)	
19-1/8"	G1 & G2	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0
	G3 & G4	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0
26-1/2"	G1 & G2	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0
	G3 & G4	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0
30"	G1 & G2	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0
	G3 & G4	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0
42"	G1 & G2	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0
	G3 & G4	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0
48"	G1 & G2	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0
	G3 & G4	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	-	-
53-1/8"	G1 & G2	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0
	G3 & G4	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0 *	-	-	-	-


* ADDL. ANCHORS REQD. AT JAMB ENDS FOR THIS SIZE AND LOAD ONLY.



EQUAL LITES

Unequal Lites Windows
Design Load Capacity - PSF

Window Width (in.)	Glass Type	Window Height (in.)											
		38-3/8" (4)		50-5/8" (6)		63" (6)		76" (8)		84" (10)		96" (12)	
19-1/8"	G1 & G2	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0
	G3 & G4	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0
26-1/2"	G1 & G2	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0
	G3 & G4	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	-	-
30"	G1 & G2	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0
	G3 & G4	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	-	-
42"	G1 & G2	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	-	-	-	-
	G3 & G4	+80.0	-120.0	+80.0	-120.0	+80.0	-120.0	-	-	-	-	-	-
48"	G1 & G2	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	-	-	-	-	-	-
	G3 & G4	+80.0	-120.0	+80.0	-120.0	-	-	-	-	-	-	-	-
53-1/8"	G1 & G2	+70.0	-70.0	+70.0	-70.0	+70.0	-70.0	-	-	-	-	-	-
	G3 & G4	+80.0	-120.0	+80.0	-120.0	-	-	-	-	-	-	-	-



UNEQUAL LITES (ORIEL TYPE)

NO. IN PARENTHESIS INDICATE NO. OF ANCHORS PER JAMB.

FOR SIZES NOT SHOWN, ROUND UP TO THE NEXT AVAILABLE WIDTH OR HEIGHT DIMENSION SHOWN ON THE TABLE.

NOTE:
GLASS CAPACITIES ON THIS SHEET ARE BASED ON ASTM E1300-16 (3 SEC. GUSTS)

FL#40096.5

JAVAD AHMAD PE, Inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com

CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS


drawing no.		REVISION			
date:	04/15/2025	No	DATE	BY	DESCRIPTION
JA-12/05-25	drawn by: MA				
	check by: BS				


SERIES 150: ECO-GUARD ALUMINUM SINGLE HUNG WINDOW (L.M.I)
LARGE MISSILE IMPACT RATED


eco window systems
ECO WINDOW SYSTEMS, LLC
8620 NW 90th ST. MIAMI, FL 33166
TEL: (305) 885-5299 FAX: (305) 885-5902


JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER

SEALED: 04-15-2025









WEEPHOLES:

W1 = 1/4" X 3/4" WEEPHOLES AT 12-1/2" FROM EACH END.


WOOD BUCKS AND METAL STRUCTURE NOT BY 'ECO WDW'. MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM AND TRANSFER THEM TO THE BUILDING STRUCTURE.

TYPICAL ANCHORS: SEE ELEV. FOR SPACING

Anchor Type	Frame Member	Substrate	Min. Edge Distance	Min. Embedment or Metal Thickness
1/4" DeWalt UltraCon +	All	Southern Pine (SG = 0.55)	1"	1-1/2"
	All	Thru 1BY Buck into Concrete (min. 3 ksi)	2-1/2"	1-1/4"
	Jambs	Thru 1BY Buck into Hollow or Filled Block (ASTM C90, min. 2 ksi)	2-1/2"	1-1/4"
	All	Concrete (min. 3ksi)	2-1/2"	1-1/4"
	Jambs	Hollow or Filled Block (ASTM C90, min. 2 ksi)	2-1/2"	1-1/4"
#14 SMS or Self Drilling Screws (Gr. 2)	All	F.B.C. Approved Mullions	3/4"	(3) Threads min. beyond metal thickness
	Head/Jambs	Aluminum 1/8" Thk. Min. (6063-T5)	3/4"	(3) Threads min. beyond metal thickness
	Head/Jambs	Steel 1/8" Thk. Min. (min. 36 ksi)	3/4"	(3) Threads min. beyond metal thickness

1. STEEL IN CONTACT WITH ALUMINUM TO BE PLATED OR PAINTED
2. ALL ANCHOR HEAD TYPES ARE ACCEPTABLE
3. SILL MEMBER IS APPROVED TO BE USED AS UNANCHORED

Mullion.



FL#40096.5

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com
CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no.
date: 04/15/2025
drawn by: MA
check by: BS
JA 1208-25

REVISION

No.	DATE	BY	DESCRIPTION


SERIES 150 ECO-GUARD ALUMINUM SINGLE HUNG WINDOW (LMI)
LARGE MISSILE IMPACT RATED


eco window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL: (305) 885-5299 FAX: (305) 885-5902


JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER


SEALED: 04-15-2025

04 | 04 of 08









FL#40096.5

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com
CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no.	JA-1206-25	drawn by:	MA
date:	04/15/2025	check by:	BS

REVISION


No.	DATE	BY	DESCRIPTION


SERIES 150: ECO-GUARD ALUMINUM SINGLE HUNG WINDOW (L.M.I)
LARGE MISSILE IMPACT RATED


eco window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902


JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER


SEALED: 04-15-2025











INSTALLATION DETAILS WITH FLUSH FRAME ADAPTER

SEE SHEETS 4 & 5 FOR WINDOW DETAILS

FL#40096.5

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral,
FL 33126
Ph: (305) 424-8001
support@ja-pe.com
CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no. JA 1206.25 | drawn by: MA
date: 04/15/2025 | check by: BS

No.	DATE	BY	DESCRIPTION


REVISION

SERIES 150: ECO-GUARD ALUMINUM SINGLE HUNG WINDOW
(FLUSH FRAME)
LARGE MISSILE IMPACT RATED


eco window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX: (305) 885-5902

JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER


SEALED: 04-15-2025




① FRAME HEAD




④ FIX. MEETING RAIL




⑤ VENT TOP RAIL



⑥ VENT BOTTOM RAIL




⑦ VENT SIDE RAIL




③ FRAME JAMB




⑧ GLAZING BEADS (8A)




⑪ SPRING LOADED LATCH



⑩ SCREW COVER



② FRAME SILL



㉓ FLUSH FRAME ADAPTER

ITEM #	PART #	QUANTITY	DESCRIPTION	MATERIAL	MANF./SUPPLIER/REMARKS
1	E151	1	FRAME HEAD	6063-T6	-
2	E152	1	FRAME SILL	6063-T6	-
3	E153	2	FRAME JAMB	6063-T6	-
4	E154	1	FIXED MTG. RAIL	6063-T6	-
5	E155	1	VENT TOP RAIL	6063-T6	-
6	E156	1	VENT BOTTOM RAIL	6063-T6	-
7	E157	2	VENT SIDE RAIL	6063-T6	-
8	E159	AS REQD.	GLAZING BEAD (LAM. GLASS)	6063-T6	-
8A	E158	AS REQD.	GLAZING BEAD (INSUL. LAM. GLASS)	6063-T6	-
9	FY116	2/VENT	SASH STOP	6063-T5	-
10	E162	AS REQD.	SCREW COVER	6063-T6	-
11	FY113	2/VENT	SPRING LOADED LATCH, AT 6" FROM ENDS	6063-T6	-
11A	-	1/LATCH	LATCH SPRING	ST STEEL	-
12	SL203P	2/VENT	SWEEP LATCH, AT 12" FROM ENDS	ZAMAK	SULLIVAN & ASSOC.
12A	#8 X 5/8"	2/LATCH	LATCH INST. SCREWS	ST STEEL	FH SMS
13	-	AS REQD.	SETTING BLOCK	EPDM	DUROMETER 80±5 SHORE A
14	#10 X 1"	AS REQD.	FRAME & VENT ASSEMBLY SCREWS	CRS	PH SMS
14A	#10 X 1-1/4"	2/CORNER	FLUSH FRAME ADAPTER FASTERNERS	CRS	FH SMS
15	E207	AS REQD.	BOTTOM RAIL SEAL - SERIES 101	NEOPRENE	ULTRAFAB
16	TR.3020	AS REQD.	GLAZING BEAD BULB	SANTOPRENE	TECHNO RUBBER
17	E163	2/VENT	SASH TOP GUIDE	DERLIN	M&M PLATICS
18	W23181	AS REQD.	FIN SEAL W'STRIPPPING	-	ULTRAFAB
19	E164	4/VENT	SASH SIDE GUIDE	DERLIN	M&M PLASTICS
19A	#6 X 3/8"	1/GUIDE	SASH GUIDE INST. SCREW	CRS	OH SMS TYPE B
20	F210	2/VENT	SASH BALANCE	-	SUPERBOOST BY BSI
20A	#8 X 1"	1/BALANCE	BALANCE INST. SCREW	ST STEEL	FH SMS
20B	21B02 UEK	1/BALANCE	BALANCE BRACKET	STEEL	CALDWELL
20C	#8 X 1/2"	2/BRACKET	BRACKET FASTENER	ST. STEEL	PH SMS
21	-	AS REQD.	GLASS SPACER	SILICONE	FRANK LOWE
22	-	1	5/16" BOX SCREEN	-	OPTIONAL
23	E161	-	FLUSH FRAME ADAPTER	6063-T6	OPTIONAL
24	-	-	INSUL. GLASS SPACER	VARIOUS	VARIOUS

FL#40096.5

JAVAD AHMAD PE, Inc
7875 NW 12th St., Suite 102 Doral,
FL 33126
Ph: (305) 424-8001
support@ja-pe.com

CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no. JA-1206-25 | drawn by: MA
date: 04-15-2025 | check by: BS

REVISION

No.	DATE	BY	DESCRIPTION


SERIES 150 ECO-GUARD ALUMINUM SINGLE HUNG WINDOW (L.M.I)
LARGE MISSILE IMPACT RATED

eco window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902

JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER


SEALED: 04-15-2025

VENT TOP CORNER




VENT BOTTOM CORNER

FRAME TOP CORNER



MEETING RAIL

FRAME BOTTOM CORNER



FLUSH FRAME ADAPTER CORNER

FL#40096.5

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com
CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no.	JA-1206-25
date:	04/15/2025
drawn by:	MA
check by:	BS

REVISION

No.	DATE	BY	DESCRIPTION

SERIES 150 ECO-GUARD ALUMINUM SINGLE HUNG WINDOW (L.M.I)
LARGE MISSILE IMPACT RATED

ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902

JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER

SEALED: 04-15-2025

08	08 of 08